

# EXECUTIVE SUMMARY

---

## 1. INTRODUCTION

M/s. Jyothi Jala Shakthi Pvt. Ltd (JJSPL), a division of M/s. Chanakya Cements Ltd of M/s. Penna Cement Industries Ltd (PCIL) group, has set up an office in Hyderabad with the objective of developing mini hydel schemes in Karnataka. As a sequel to its policy of encouraging private entrepreneurs to set up mini hydel schemes in the state, the Government of Karnataka (GOK) has awarded the proposed Aidabhavi Mini Hydel Project (AMHP) to JJSPL.

This project is called Aidabhavi Mini Hydel Project (AMHP).

The 24.75 MW (3 x 8.25 MW) capacity AMHP is planned to be erected across the Krishna River, near Aidabhavi Village of Lingsugur Taluk in Raichur District. JJSPL, through its sister concern called M/s. Pusala Power Projects Pvt. Ltd (PPPPL), has presently taken up execution of the 6 MW Kenchanguddam Mini Hydro Project across the Tungabhadra river in Bellary district.

## 2. PROPOSED PROJECT

The proposed AMHP consists of 3 turbines of 8.25 MW capacity each. It envisages to take advantage of the spills/releases from the Guntagola Mini Hydel Plant (GMHP) and a head of 20 m available in the form of a series of rapids present in the riverbed over a length of about 12 km to generate power. After power generation, the water will be released back into the river through a 5.5 km tailrace canal. The generated power will be transferred to Lingsugur Substation of Karnataka Power Transmission Corporation Limited (KPTCL), about 12 km from the proposed project site.

## 3. ADVANTAGES OF HYDROPOWER

- Saves scarce fuel reserves.
- Cost of generation-O&M is lower than that of other sources of energy.
- Most potent source of renewable energy for sustainable development.
- Efficiency is highest among the renewable energy sources.
- Inflation-free production.
- Cost of generation is free from inflationary effects after the initial installation.
- Non-polluting and hence environment-friendly.
- Long life - The first hydro project at Darjeeling completed in 1897 is still in operation. The second project, the Shivasamudram project, which came up in Karnataka in 1902, is still generating power. It has the longest life among other renewable energy sources.

- Being located in remote regions leads to development of interior backward areas (education, medical, road communication, telecommunication, etc.).
- Ability to start and stop quickly and instantaneous load acceptance/rejection makes it suitable to meet peak demand and for enhancing system reliability and stability.
- Has higher efficiency (over 90 per cent) compared to thermal (35 per cent) and gas (around 50 per cent).
- Can provide attendant benefits of irrigation, flood control, drinking water supply, recreation, tourism, etc.

#### 4. PROPOSED SITE LOCATION

The proposed AMHP is situated on the right bank of Krishna River near Aidabhavi village, in Lingsugur taluk of Raichur district in Karnataka State. The Project is about 28 km (by road) from Lingsugur Town. The nearest highway is 10 km away which is a State Highway (SH-19) connecting Lingsugur & Gulbarga. The Narayanpur dam is around 33 km upstream of the proposed powerhouse. Lingsugur is around 90 km from Raichur while Bangalore is around 450 km from the proposed site.

The district headquarters, Raichur, is about 110 km to the west of the project site. The 297 MW Almatti Hydro Power Station & 24 MW Chayadevi Mini Hydel Project are 91 km & 23 km upstream of the proposed site, respectively. The Narayanpur Dam is 33 km upstream of the power canal. There are two proposed mini hydel projects just upstream of the project site. These are (i) the 24.75 MW Tugli Mini Hydel Project (TMHP) around 19 km upstream (power canal) and (ii) the 24.75 MW Guntagola Mini Hydel Project (GMHP), the tailrace canal of which forms the power canal of AMHP is 10 km from the power house.

The geographical co-ordinates of the project site are 16<sup>0</sup>18'43" N Latitude and 76<sup>0</sup>32'48" E Longitude.

#### 5. JUSTIFICATION FOR THE PROJECT SITE AND ALTERNATIVE SITES CONSIDERED

A hydel project is a site-specific project for the following reasons:

- There should be sufficient flow of water in the stream to generate power.
- There should be sufficient head difference available for running the turbines.
- The site should be easily accessible.
- Power evacuation facilities should be available within a short distance.

Since the proposed project site near Aidabhavi village satisfies the above criteria and allotted by the Government of Karnataka accordingly, no alternative sites were considered for the project. Moreover, the proposed project site near Aidabhavi village has the following advantages.

- a. **No Diversion Structure** – The proposed project will not have a diversion structure. It is proposed to utilise the flows from the GMHP powerhouse for power generation.

- b. **Easy Approach** – The powerhouse of the proposed project is about 0.5 km from a pucca road connecting to the Aidabhavi village. A kutchra cart track of 0.5 km connects to the powerhouse area. The project does not need extensive construction of approach road to powerhouse and, therefore, there is no risk of environmental damage.
- c. **Less Human Habitation in the Vicinity** – The powerhouse is to be set up around 2 km from Aidabhavi village. Thus, the project implementation will not have any impact on the population and their activities. Moreover, the powerhouse is located and the power canal is away from this area.
- d. **Easy availability of construction Material** – The basic construction material, particularly boulders, will be available from the project excavated material itself, thereby reducing the procurement cost and the environmental impact due to their transportation.
- e. **No/minimal Impact on surroundings** – The proposed project will have its components next to the River Krishna. Hence, it will have no/minimal impact on the surroundings located in the study area.
- f. **No/less Waste Generation** – It is proposed to utilise most of the project excavated material for the construction of the various components of the project.

In view of the above, the proposed project site near Aidabhavi village is considered appropriate for construction of the mini hydel project.

## 6. DETAILS OF THE HYDEL SCHEME

The proposed project is a mini hydroelectric power generation facility, which will use the water in Krishna River for generation of electricity. It is proposed to continue the tailrace canal of GMHP into **Power Canal** of AMHP through an **Intake Canal** located at the right bank. The flows from the power canal are conveyed to the powerhouse through a **Forebay** and **Penstock Intake**. Three independent **Penstocks** carry water from the forebay to the powerhouse.

The **Powerhouse** accommodates three **Turbine Generator (TG)** units, of 8.25 MW capacity each. It is proposed to locate the powerhouse on the right bank of the river. After generation of power, water will be released back into the river through a **Tailrace Canal**.

Total installed capacity of the proposed AMHP is **24.75 MW (3x8.25 MW)**. The average annual energy for the total installed capacity of 24.75 MW is estimated at **65 Mu**, whereas the net energy available after accounting for 1.0 per cent for station auxiliary consumption and non-availability exigencies of grid at 2.0 per cent is estimated to be **63.7 Mu**.

The generated power will be evacuated from the powerhouse to 110 kV switchyard of Karnataka Power Transmission Corporation Limited (KPTCL) at Lingsugur substation by a double circuit, 12 km long 110 kV transmission line.

## 7. INFRASTRUCTURE REQUIREMENT

The proposed AMHP will require the following infrastructure for construction and operation and maintenance of the hydropower station.

### 7.1 LAND

Total land requirement estimated for the proposed project is as given below.

**Table 1: Land Requirement for Proposed AMHP**

<b>Structure</b>	<b>Area (acres)</b>
Diversion Structure	-
Power Canal	29.00
Power House and Switch Yard, Pen Stock	2.00
Tail Pond and Tail Race Canal	19.00
Approach Roads	1.00
Dump Yard	5.00
<b>Total</b>	<b>56.00</b>

### 7.2 WATER

Power generation not have any process of water consumption. Water will be need only for construction and domestic purposes. Water requirement during construction phase has been estimated at about 10,000 litres per day for construction and domestic purposes. Water for construction purpose will be drawn from the borewell. Potable water for the AMHP staff will be obtained from borewell during the construction and operation phases.

### 7.3 POWER

Power for construction purpose will be tapped from the near to KPTCL lines. Further, a 200 kVA rating DG set is proposed to be installed to cater the needs of power requirements during construction. This DG set will act as stand-by when KPTCL power is not available. Subsequently, after commissioning of the hydel scheme this DG set is proposed to be used for powerhouse auxiliary requirements whenever KPTCL supply is not available.

### 7.4 ACCESS ROAD

The powerhouse is proposed to be located near Aidabhavi. Approach road to the powerhouse location shall initially be from the road leading towards the Aidabhavi village. A separate service road along the power canal as well as powerhouse will also be required. A total road length of about 10 km has to be constructed for providing access to the project.

### 7.5 MANPOWER

Manpower requirement for the proposed project during its construction stage will be approximately 125 whereas about 30 personnel will be employed during the operation phase of the facility. The plant will operate in three shifts.

## **7.6 SITE OFFICE AND QUARTERS**

Residential accommodation for JJSPL staff during construction and subsequently during operation and maintenance is necessary. Permanent offices of JJSPL operation staff will be located within the powerhouse building. Residential accommodation for JJSPL staff during construction period and subsequently for O&M of power station can be provided at Aidabhavi village or Tammankal village, or Lingsugur town. Temporary site offices and store yards during construction can be located at the project site near the powerhouse on the right bank. Actual allocation of space for Site offices and Quarters would be finalized only after the process of land acquisition is complete.

## **8. ENVIRONMENTAL IMPACT ASSESSMENT (EIA)**

JJSPL has entrusted the Centre for Symbiosis of Technology, Environment & Management (STEM) to carry out a Rapid Environmental Impact Assessment (REIA) study of their proposed mini hydel project near Aidabhavi village. The objective of the REIA study is to identify, predict and assess the likely environmental impact of the proposed AMHP during its construction and operational stages. The REIA study also aims at developing an appropriate Environmental Management Plan (EMP) for mitigating adverse environmental impact of the proposed project, if any.

The study area is 10 km radius circle with respect to the proposed project site (starting of power canal) as centre for assessing the potential environmental impacts of the proposed AMHP. This project site is located on the boundary of the Raichur and Gulbarga districts. The study area is spread over the two districts. It includes villages in the Lingsugur taluk of Raichur district and Shorapur taluk of the Gulbarga district.

### **8.1 AIR ENVIRONMENT**

Micrometeorological data of last five years (1999 to 2003) monitored at the Raichur Observatory of the India Meteorological Department (IMD) has been used as baseline data for this study.

Based on the micrometeorological data of 1999 to 2003 recorded at Raichur, it can be seen that the monthly mean relative humidity recorded at 0830 hrs was in the range of 31 per cent to 77 per cent, whereas that at 1730 hrs was in the range of 18 per cent to 68 per cent. Similarly, the monthly mean temperature recorded varied from a minimum of 15.0°C to a maximum of 42.6°C. The average rainfall is 608.2 mm.

The predominant wind direction is shown from directions between west and south-west from February to September, and from directions between north, east and north-east during winter October to January.

In order to assess the baseline status of ambient air quality in the study area, ambient air quality monitoring was carried out at the two locations. The results indicate that the concentration of the ambient air quality parameters at all the monitoring locations in the study area are within the applicable National Ambient Air Quality Standards (NAAQS) for sensitive areas.

## **8.2 NOISE**

To establish the baseline noise scenario, Noise standards prescribed for industrial area have been considered for comparative assessment of the noise levels. Noise level monitoring was carried out at two different locations and that results are considered for assessing the baseline noise levels.

## **8.3 WATER**

Proposed project is based on Krishna River. This is the major surface water body within the study area. The perennial river divides into two branches near Jaldurga. These branches join together along with Don River again about 18 km downstream near Guntagola.

Water samples were collected from the surface and ground water sources in order to establish the baseline status of water quality in the study area. The water samples were analysed for pH value, colour, TDS, TSS, Oil & Grease, BOD, COD, DO, Chlorides, SO<sub>4</sub>, NO<sub>3</sub>, Hardness and total Faecal Coliform.

## **8.4 LAND**

Thirty nine per cent of the study area comprises “un-irrigated land” and only 32 per cent of the area is being irrigated. The “cultivable waste land” is 2 per cent whereas about 22 per cent of the area falls under “area not available for cultivation”. Only about, 5 per cent of the land in the study area (10 sq. radius) is “forest land”. However, there is no forest land involved in the proposed project area.

## **8.5 TERRESTRIAL ECOLOGY**

### **8.5.1 Forest**

The study area of 10 km radius with respect to the proposed project site fully covers Guntagola Reserve Forest.

### **8.5.2 Flora**

The study area is not rich in vegetation. List of trees and plants found in agricultural land and the road side, species in forest and unclassified lands, grasses, agricultural crops, etc. are given in the relevant chapter of the report.

### **8.5.3 Fauna**

The few mammals and reptiles found in the area are listed in the relevant chapter. Since Krishna River a perennial river flows through in the study area both wetland birds and terrestrial birds can be sighted in this area. Some of the birds visit the study area during winter.

## **8.6 AQUATIC ECOLOGY**

There is no significant fishing activity taking place at the project site. Based on the discussion with the authorities of the Fisheries Department, the fish species in the

Krishna river are listed in the relevant chapter. The local fishermen confirmed the same during the site visit.

## **8.7 SOCIO-ECONOMIC ENVIRONMENT**

The study area (i.e. area within 10 km radius of the proposed AMHP site) falls in the Lingsugur and Shorapur taluks of Raichur and Gulbarga districts, respectively. total population of the study area is 55,759, of which 28,174 are male and 27,585 are female. The scheduled castes and scheduled tribes population of the study area is 29,065 (i.e. 52.1 per cent), of which 14,595 are male and 14,470 are female. Average population density in the study area is approximately 160 persons/km<sup>2</sup>, which shows sparse habitation in the area.

The overall literacy rate in the study area is 25.6 per cent, whereas male and female literacy rates are 33.4 per cent and 17.6 per cent, respectively. Primary education is generally available in the villages.

All the villages in the study area are provided with electricity and drinking water supply. Water availability is either through handpump or by well water. Very few villages have tap water facility and no village has Over Head Tank water supply.

The common mode of transportation in the study area is through State and private transport buses. A major road SH-19 passes through the study area. Most of the villages in the study area are connected by kutcha / pucca roads. The state transport (KSRTC) buses are available on internal routes, in addition to the private small vehicles like jeep and tempo.

There are two Primary Health Centres (PHC) available in the study area. Medical facilities are available at the taluk headquarters, Lingsugur. These include well-equipped government and private hospitals, dispensaries, family planning centres, etc.

## **9. BENEFITS OF THE PROPOSED PROJECT**

The benefits and major objectives expected to be achieved by the proposed AMHP are presented as follows.

### **9.1 INCREASED POWER AVAILABILITY**

The AMHP is expected to generate 65 mu of electric power in addition to existing supply, which will help partially improve the power availability in the region. Also, it is significant for off-grid or on-grid, rural, in far-flung isolated communities having no chances of grid extension or increase in power availability for years to come.

### **9.2 LOWER COST FOR POWER GENERATION**

This power generation process not have running cost of fuel. Capital investment is the only major cost for this project. The proposed project is a mini hydel project with simple design of turbines, generators and civil works. Therefore, the project takes lesser time for its construction and commissioning, reducing the related costs substantially. Moreover, since a hydel scheme is based on water, which is available

free of cost, and does not involve use of any fossil fuels, expenditure towards fuel procurement and transportation are saved. As a result, the levelized cost of generation from small hydro power project would be less than half that of thermal power production cost. Auxiliary consumption is much less than that of thermal, which is around 10 per cent. This is an inflation-free energy development involving minimal operation and maintenance cost.

### 9.3 MINIMAL ENVIRONMENTAL IMPACTS

As no chemical processes are involved in transfer of energies, it does not cause any emissions into environment or generation of wastes. Basically, there is no environmental damage during operational phase. Hydro represents non-consumptive, non-radioactive and non-polluting use of water resources. Hydropower is a free gift of nature – clean, economical, perennial and inexhaustible i.e. renewable. The small hydel projects are considered to have minimal impact on the surrounding environment due to negligible area of submergence, and absence of gaseous emissions or solid waste generation such as fly ash. Moreover, small hydros are simple to operate and easy to maintain.

### 9.4 SOCIO-ECONOMIC BENEFITS

Around 125 personnel will be employed for a period of about 18 months, providing a direct employment potential to the local villagers. Moreover, indirect employment (secondary support job opportunities) will be generated by the power project, and the area around it will have the potential to be developed into a picnic spot.

**Table 2: Expected Beneficial Impacts of the Project**

a. The economy of the area improves due to permanent infusion of money through salaries to the employees as well as income to the indirectly employed people.
b. The local economy will also improve, if the project site is developed as a picnic spot. Development of the project site as a picnic spot will further improve aesthetics of the site.
c. Greenbelt development around the project site will improve the flora in the area and also aesthetics of the area.
d. Employment to about 125 persons during construction and 30 persons during operation phase as direct services, while there will also be indirect employment for supporting services.
e. The project can be suitably modified in future to provide attendant benefits of irrigation, flood control, drinking water supply, recreation, tourism, etc.
f. The power generated will be made available over a larger region. The positive impacts of the project will, therefore, not be restricted to the local population alone.
g. Transport, Communication and other community facilities will improve. There will be considerable socio-economic development in the surrounding villages.
h. Will help in development of the interior backward areas.
i. Increased availability of electric power in the region.

## 10. POTENTIAL ENVIRONMENTAL IMPACTS AND MITIGATIVE MEASURES

The likely impacts of the proposed AMHP, during its operation phase, on the surrounding environment are summarised in **Tables 3** and **4** respectively.

Table 3: Construction Phase: Potential Impacts and Mitigative Measures

Sl. No.	Environmental Components	Potential Impacts	Source of Impacts	Mitigative Measures		Remarks
1.	Air quality	Increased SPM concentration in ambient air.	Construction equipment, vehicular traffic, excavation, concreting, etc.	Vehicular check; water spraying for dust suppression; Proper road maintenance	●	Minor negative but temporary
2.	Noise	Increased noise levels	Construction equipment, various construction activities	Equipment selection & maintenance; usage of ear plugs/muffs by the construction workers	●	Minor negative impact but temporary
3.	Water	Demand of water supply in addition to extraction from borewells. Local increase in suspended solids	Construction equipment, concrete mixing & curing, cleaning, workers' domestic needs dust suppression etc. Erosion due to excavation activities	Equipment selection, steam curing, high pressure hose for cleaning. Plantation around site before construction. Recharge of borewell	●	Minor negative impact on surface water
					●	No impact on ground water
4.	Land	Construction wastes, unstable slopes, soil erosion	Construction waste (excavated material)	Appropriate waste disposal measures; slope stabilization and greenbelt development.	●	No impact on land use.
					●	Minor negative on soil quality
5.	Aesthetics	Land clearance, construction waste.	Construction activities and waste	Appropriate waste disposal and greenbelt development. Alternative passages.	●	Minor negative.














Sl. No.	Environmental Components	Potential Impacts	Source of Impacts	Mitigative Measures		Remarks
6.	Terrestrial Ecology	Impact on top soil & existing ecosystem in the vicinity of the site.	Construction activities in a 5km stretch	Low noise generating equipment, soil binding vegetation, greenbelt development. Providing passages.		Minor negative and temporary.
7.	Aquatic Ecology	Change in flow, increase in suspended solids and TDS	Construction activity of diversion canal, power house and tailrace canal	Providing rocky boulders/structures near the powerhouse to restore the original habitat to the extent possible.		Short term Minor negative impact
8.	Socio-economic factors					
(i)	Population	No impact	Construction jobs	Employing local people, Providing proper facilities and community services for the workers		No impact
(ii)	Education	No impact	-	Employing local people		No impact
(iii)	Employment	Increase in direct & indirect employment opportunities	Construction jobs to the local manual laborers and professionals	Employing local people to the extent possible.		Moderate positive
(iv)	Infrastructure facilities & Community services	Disturbance of existing infrastructure & community facilities	Construction activities	Alternative arrangements		Minor negative and temporary
9.	Population displacement and rehabilitation	None	No displacement of population	-		No impact

Table 4: Operation Phase: Potential Impacts and Mitigative Measures

Sl. No.	Environmental Components	Potential Impacts	Source of Impacts	Mitigative Measures		Remarks
1.	Air quality	None	Occasional vehicular movement	Green belt development, usage of good quality fuels.	●	No impact.
2.	Noise	Increased noise levels but below the prescribed standard.	Operation of noise generating equipment like turbines, pumps & compressors	Equipment will be provided with noise reduction measures such as acoustic barriers, vibration pads etc. Maintenance routine for the equipment. Green belt development.	●	No impact.
3.	Water	None	None	Minimize water usage by water conservation, reuse of treated sewage for greenbelt irrigation. No discharge of untreated wastewater into the river. Mandatory flows shall be maintained.	●	No impact
4.	Land	None	Project activities	Development of a systematically managed green belt to maintain ecology of the area. Appropriate disposal of solid waste, garbage.	●	No impact on landuse
					●	No impact on soil quality
5.	Aesthetics	Better environment	Development of project site as picnic spot	Development of greenery and site as picnic spot	●	Minor positive impact
6.	Terrestrial Ecology	Minor loss of trees, obstruction to animals to access the river.	Project activities	Greenbelt development. Providing suitable access to river for animals.	●	No impact

Sl. No.	Environmental Components	Potential Impacts	Source of Impacts	Mitigative Measures		Remarks
7.	Aquatic ecology	Change in flow, passage for fishes.	Diversion of flow	Mesh of appropriate size will be provided at the inlet points of the intake canal to prevent entry of fish along with water into the turbines.		Minor impact and temporary – Water will overflow over the Diversion structure. Also, water will be released back into the river within a dist. (5000 m).
8.	Socio-economic factors					
(i)	Population	<i>Small increase in population.</i>	Direct / indirect job opportunities, secondary services	Employment of local people to the extent possible		No impact
(ii)	Education	None	None	Employment of local people to the extent possible		No impact
(iii)	Employment	Better employment opportunities	Operation phase direct & indirect project and social requirements, Development of the site as picnic spot	Employment of local people to the extent possible		Moderate positive
(iv)	Infrastructure facilities & Community services	Improvement in infrastructure facilities & community services	Operation phase project and social requirements	-		Minor positive
9.	Population displacement and rehabilitation	None	No displacement of population	-		No impact

executive summary .....	i
1. Introduction.....	i
2. PROPOSED PROJECT .....	i
3. Advantages of Hydropower.....	i
4. proposed site LOCATION .....	ii
5. JUSTIFICATION FOR THE PROJECT SITE AND ALTERNATIVE SITES CONSIDERED.....	ii
6. DETAILS OF THE HYDEL SCHEME.....	iii
7. INFRASTRUCTURE REQUIREMENT .....	iv
7.1 Land.....	iv
7.2 Water .....	iv
7.3 Power.....	iv
7.4 Access Road.....	iv
7.5 Manpower .....	iv
7.6 Site Office and Quarters.....	v
8. Environmental Impact Assessment (EIA).....	v
8.1 Air Environment .....	v
8.2 NOISE.....	vi
8.3 WATER.....	vi
8.4 LAND .....	vi
8.5 TERRESTRIAL ECOLOGY .....	vi
8.6 AQUATIC ECOLOGY .....	vi
8.7 SOCIO-ECONOMIC ENVIRONMENT.....	vii
9. BENEFITS OF THE PROPOSED PROJECT.....	vii
9.1 Increased power availability .....	vii
9.2 Lower cost for power generation .....	vii
9.3 Minimal environmental impacts .....	viii
9.4 Socio-economic benefits .....	viii
10. POTENTIAL ENVIRONMENTAL IMPACTS AND MITIGATIVE MEASURES .....	viii

Table 1: Land Requirement for Proposed AMHP

Table 2: Expected Beneficial Impacts of the Project

**Table 3: Construction Phase: Potential Impacts and Mitigative Measures**

**Table 4: Operation Phase: Potential Impacts and Mitigative Measures**